

Certificate no. TAI-FS-C-21-0048

WE HEREBY CERTIFY THAT

Product description

**2-WAYS FULLY WELDED SIDE ENTRY TRUNNION
MOUNTED BALL VALVE**

Models

SERIES W

Manufacturer

**DAFRAM S.p.A.
Via San Raffaele 1
I-20121 Milano (MI)**

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION
SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-21-0101

Expiry date 27.04.2024

Issue date 28.04.2021

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
28.04.2021, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

Annex to certificate no. TAI-FS-C-21-0048

Type	A
HFT	0
Safety functions	1. Close / Open upon the demand of the actuation system 2. Close upon the demand of the actuation system, with inline tightness when in closed position
Mode of operation	Low Demand Mode


Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Self-relieving / Double piston effect - No PST	1	3,38E-08	0,00E+00	0,00E+00
Self-relieving / Double piston effect - With PST	1	3,04E-09	3,08E-08	0,00E+00
Self-relieving - No PST	2	5,17E-08	0,00E+00	0,00E+00
Self-relieving - With PST	2	2,09E-08	3,08E-08	0,00E+00
Double piston effect - No PST	2	5,14E-08	0,00E+00	0,00E+00
Double piston effect - With PST	2	2,07E-08	3,08E-08	0,00E+00

Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1H:	Applied	Route 2H:	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

Remarks:

- Self-relieving configuration: both upstream and downstream seats shall be of self-relieving type (i.e. single barrier in the flow direction)
- Double piston effect configuration: at least downstream seat shall be of double piston effect type (i.e. double barrier in the flow direction)
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual MAE11009.

END OF CERTIFICATE



TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
28.04.2021, Monte Roberto (AN)

Ing. Crescenzo Di Fratta